

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
	SOCO											
1	CO SPR 11	7	C	130	130-Roosevelt Elementary Cha	1969	46,252	The pay their own utlity bill dircetly.	-	-	-	-
2	CO SPR 11	7	C	142	142-McAuliffe Elementary Sch	2007	61,773	Geothermal	7.01	23.91	1.72	25.63
3	CO SPR 11	7	C	143	143-Freedom Elementary Scho	2007	62,532	Geothermal	7.05	24.04	3.68	27.72
4	CO SPR 11	7	C	136	136-Buena Vista Montessori Sc	1956	29,209	Geothermal	6.78	23.14	11.82	34.96
5	CO SPR 11	7	C	119	119-King Elementary School	1984	45,127	Rooftop Mechanical Cooling	6.33	21.58	22.66	44.24
6	CO SPR 11	7	C	131	131-Rudy Elementary School	1978	42,421	Rooftop Mechanical Cooling	6.54	22.30	22.95	45.26
7	CO SPR 11	7	C	126	126-Queen Palmer Elementary	1948	42,689		5.24	17.89	32.95	50.84
8	CO SPR 11	7	C	109	109-Chipeta Elementary Schoo	1987	63,600	Chiller	6.73	22.95	29.34	52.29
9	CO SPR 11	7	C	128	128-Pike Elementary School (A	1956	28,596		4.59	15.65	38.78	54.43
10	CO SPR 11	7	C	102	102-Audubon Elementary Scho	1956	47,332	Chiller	4.78	16.30	41.56	57.86
11	CO SPR 11	7	C	139	139-Trailblazer Elementary Sch	1998	57,470	Rooftop Mechanical Cooling	7.52	25.67	32.24	57.91
12	CO SPR 11	7	C	123	123-Madison Elementary Scho	1964	36,741		4.67	15.95	42.11	58.06
13	CO SPR 11	7	C	124	124-Midland Elementary Scho	1956	31,510	Rooftop Mechanical Cooling	8.60	29.33	28.79	58.12
14	CO SPR 11	7	C	101	101-Adams Elementary School	1963	43,512		4.53	15.45	44.96	60.41
15	Falcon	7	D	A	Meridian Ranch Elementary	2006	57,227	Roof Top Units	6.95	23.72	37.06	60.78
16	CO SPR 11	7	C	135	135-Twain Elementary School	1962	56,594		5.20	17.75	43.21	60.96
17	CO SPR 11	7	C	137	137-Whittier Elementary Scho	1901	32,911	Chiller	5.18	17.67	43.98	61.65
18	Falcon	7	D	G	Odyssey	2006	50,265	Roof Top Units	7.31	24.93	36.98	61.92
19	Falcon	7	D	C	Falcon Elementary	1982	44,201	Roof Top Units	6.30	21.50	40.69	62.19
20	Falcon	7	D	D	Spring Ranch	2006	60,659	Roof Top Units	7.63	26.04	36.71	62.75
21	CO SPR 11	7	C	103	103-Bates Elementary School	1957	35,274		5.38	18.37	45.97	64.34
22	CO SPR 11	7	C	120	120-Lincoln Elementary Schoo	1948	41,919		5.03	17.16	47.35	64.51
23	CO SPR 11	7	C	107	107-Columbia Elementary S	1969	29,448	Rooftop Mechanical Cooling	8.55	29.18	36.42	65.60
24	CO SPR 11	7	C	134	134-Taylor Elementary School	1953	29,229		6.26	21.35	44.25	65.60
25	CO SPR 11	7	C	121	121-Longfellow Elementary Sc	1959	41,447		6.45	22.02	44.63	66.65
26	CO SPR 11	7	C	133	133-Stratton Elementary Scho	1953	37,607		4.93	16.82	50.22	67.04
27	CO SPR 11	7	C	138	138-Wilson Elementary School	1969	43,687	Rooftop Mechanical Cooling	8.15	27.82	41.07	68.89
28	Falcon	7	D	F	Evans	2003	60,443	Roof Top Units	6.50	22.17	47.37	69.54
29	CO SPR 11	7	C	118	118-Keller Elementary School	1971	38,823	Rooftop Mechanical Cooling	8.64	29.47	42.43	71.89
30	Falcon	7	D	H	Ridgeview	2002	63,122	Roof Top Units	7.48	25.53	48.25	73.78
31	CO SPR 11	7	C	114	114-Hunt Elementary School	1902	56,401		5.19	17.72	56.32	74.04
32	CO SPR 11	7	C	108	108-Edison Elementary School	1956	36,085		6.95	23.71	50.76	74.48

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
33	CO SPR 11	7	C	132	132-Steele Elementary School	1953	29,041	Rooftop Mechanical Cooling	9.01	30.75	44.69	75.44
34	Falcon	7	D	E	Remington	1999	52,664	Roof Top Units	8.00	27.28	48.75	76.03
35	CO SPR 11	7	C	125	125-Monroe Elementary School	1964	47,633		5.48	18.70	59.81	78.51
36	CO SPR 11	7	C	129	129-Rogers Elementary School	1960	40,071	Rooftop Mechanical Cooling	6.46	22.04	57.09	79.14
37	Falcon	7	D	B	Woodmen Hills	2000	61,803	Roof Top Units	7.38	25.20	55.97	81.17
38	CO SPR 11	7	C	140	140-Scott Elementary School	1998	55,341	Rooftop Mechanical Cooling	9.48	32.33	50.04	82.38
39	CO SPR 11	7	C	127	127-Penrose Elementary School	1973	37,889	Rooftop Mechanical Cooling	9.32	31.79	51.12	82.91
40	Falcon	7	D	I	Stetson	2000	62,243	Roof Top Units	7.36	25.10	62.69	87.80
41	CO SPR 11	7	C	111	111-Grant Elementary School	1966	45,273	Rooftop Mechanical Cooling	9.66	32.95	57.03	89.99
42	CO SPR 11	7	C	104	104-Bristol Elementary School	1971	31,290	Rooftop Mechanical Cooling	10.51	35.85	57.52	93.36
43	CO SPR 11	7	C	122	122-Martinez Elementary School	1988	50,394	Rooftop Mechanical Cooling	8.12	27.71	66.01	93.71
44	CO SPR 11	7	C	106	106-Carver Elementary School	1971	38,796	Rooftop Mechanical Cooling	10.58	36.09	58.50	94.59
45	CO SPR 11	7	C	110	110-Fremont Elementary School	1973	37,858	Rooftop Mechanical Cooling	11.23	38.33	58.13	96.46
46	CO SPR 11	7	C	116	116-Jackson Elementary School	1966	29,034	Rooftop Mechanical Cooling	11.86	40.47	60.09	100.56
47	CO SPR 11	7	C	112	112-Henry Elementary School	1971	39,930	Rooftop Mechanical Cooling	11.85	40.44	64.35	104.79
48	CO SPR 11	7	C	113	113-Howbert Elementary School	1959	30,888		7.44	25.38	80.60	105.97
	DENVER AREA											
1	Denver	6	D	5	Ash Grove	1953	39,536	roof top unit	-	-	-	-
2	Denver	6	D	10	Blair	2004	68,798	central	-	-	-	-
3	Denver	6	D	35	Escalante-Bigg Academy	2011	20,563	roof top unit	-	-	-	-
4	Denver	6	D	88	Swigert McAuliffe	2011	93,141	central	-	-	-	-
5	Denver	6	D	75	Rosedale Elementary	1924	38,484	none	0.51	1.74	-	1.74
6	Littleton	6	A	J	North	1949	34,904	Central Plant: Air Cooled Chiller	5.50	18.78	9.84	28.62
7	Littleton	6	A	B	Centennial	1960	47,269	Central Plant: Air Cooled Chiller	1.25	4.28	27.83	32.11
8	Douglas Co.	6	G	37	Roxborough Intermediate	2007	68,751	CHW System, HW reheat	5.80	19.80	16.00	35.80
9	Douglas Co.	6	G	45	Stone Mountain Elementary	2007	73,146	CHW System, HW reheat	5.56	18.96	19.50	38.45
10	Douglas Co.	6	G	8	Clear Sky Elementary	2008	73,146	CHW System, HW reheat	6.34	21.62	19.33	40.95
11	Littleton	6	A	A	Ames	1963	44,593	Central Plant: Air Cooled Chiller	4.37	14.89	28.10	43.00
12	Littleton	6	A	H	Lenski	1979	44,413	Central Plant: Air Cooled Chiller	7.86	26.83	16.63	43.46
13	Littleton	6	A	G	Hopkins	1962	45,527	Central Plant: Air Cooled Chiller	5.68	19.37	24.94	44.31
14	Douglas Co.	6	G	40	Sage Canyon Elementary	2010	73,146	Displacement Ventilation/ Indirect Ev	5.32	18.15	27.47	45.61
15	Douglas Co.	6	G	39	Saddle Ranch Elementary	1999	68,751	CHW System, HW reheat	6.00	20.46	25.41	45.87

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
16	Douglas Co.	6	G	18	Gold Rush Elementary	2008	73,146	CHW System, HW reheat	6.35	21.67	24.49	46.16
17	Littleton	6	A	L	Runyon	1969	40,103	Central Plant: Air Cooled Chiller	7.72	26.34	21.27	47.61
18	Littleton	6	A	F	Highland	1958	45,328	Central Plant: Air Cooled Chiller	5.56	18.97	28.92	47.89
19	Littleton	6	A	K	Peabody	1961	42,081	Central Plant: Air Cooled Chiller	6.34	21.62	27.83	49.45
20	Douglas Co.	6	G	24	Mammoth Heights Elementary	2007	73,146	CHW System, HW reheat	6.82	23.29	26.97	50.26
21	Littleton	6	A	P	Wilder	1974	41,229	Rooftop Air Handlers With DX Cooling	8.83	30.14	21.23	51.37
22	Littleton	6	A	E	Franklin	1963	47,531	Central Plant: Air Cooled Chiller	6.99	23.86	29.22	53.08
23	Littleton	6	A	O	Whitman	1961	40,728	Central Plant: Air Cooled Chiller	5.65	19.26	35.07	54.34
24	Littleton	6	A	D	Field	1962	48,260	Central Plant: Air Cooled Chiller	7.30	24.89	29.65	54.54
25	Denver	6	D	99	Wyman Elementary	1975	40,538	central	5.69	19.41	37.23	56.64
26	Denver	6	D	57	Lincoln Elemementary	1904	50,126	none	3.67	12.53	45.14	57.67
27	Littleton	6	A	M	Sandburg	1967	44,888	Central Plant: Air Cooled Chiller	6.36	21.69	36.21	57.90
28	Denver	6	D	45	Grant Ranch	2000	89,553	central	9.33	31.83	26.23	58.06
29	Denver	6	D	98	William Roberts	2006	93,702	ground source heat pumps	13.00	44.34	14.36	58.70
30	Denver	6	D	78	Schenck	1958	67,612	none	5.02	17.12	42.59	59.71
31	Douglas Co.	6	G	35	Renaissance Expeditionary Ma	2006	35,863	Rooftop DX, gasfired	12.80	43.66	16.23	59.89
32	Douglas Co.	6	G	5	Castle Rock Elementary	1984	52,907	Rooftop DX, HW reheat	8.60	29.33	30.85	60.18
33	Denver	6	D	21	Columbian Elementary	1984	42,857	central	7.97	27.20	33.75	60.95
34	Denver	6	D	94	Waller	2006	98,362	central	8.87	30.27	31.06	61.32
35	Douglas Co.	6	G	4	Buffalo Ridge Elementary	1997	53,159	Rooftop DX, HW reheat	7.49	25.57	35.87	61.44
36	Littleton	6	A	N	Twain	1972	37,194	Rooftop Air Handlers With DX Cooling	7.28	24.84	38.04	62.87
37	Douglas Co.	6	G	3	Bear Canyon Elementary	1990	50,237	Rooftop DX, HW reheat	3.96	13.51	49.66	63.17
38	Littleton	6	A	C	East	1955	37,903	Central Plant: Air Cooled Chiller	5.98	20.41	43.43	63.84
39	Douglas Co.	6	G	6	Cherokee Trail Elementary	1989	53,237	Rooftop DX, HW reheat	8.85	30.19	33.79	63.98
40	Denver	6	D	69	Oakland Elementary	1984	68,485	central	7.39	25.21	39.09	64.30
41	Douglas Co.	6	G	44	South Street Elementary	1972	52,287	Rooftop DX, gasfired	8.63	29.46	34.92	64.38
42	Denver	6	D	47	Greenlee Elementary	1950	62,801	none	5.09	17.36	47.13	64.48
43	Denver	6	D	76	Sabin World School	1958	80,537	none	4.41	15.04	50.24	65.28
44	Douglas Co.	6	G	23	Lone Tree Elementary	2007	57,509	CHW System, HW reheat	7.96	27.17	38.62	65.79
45	Denver	6	D	95	Westerly Creek	2003	71,932	central	12.22	41.69	24.16	65.85
46	Denver	6	D	91	University Park Elementary	1924	56,853	none	3.27	11.15	55.27	66.42
47	Douglas Co.	6	G	12	Eagle Ridge Elementary	1989	53,237	Rooftop DX, HW reheat	9.21	31.41	35.05	66.46
48	Douglas Co.	6	G	30	Pine Lane Elementary - North	1980	51,938	Rooftop DX, gasfired	7.80	26.60	39.91	66.51

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
49	Denver	6	D	90	Traylor Academy	1968	58,156	none	7.06	24.08	42.92	67.00
50	Douglas Co.	6	G	46	Summit View Elementary	1992	53,159	Rooftop DX, HW reheat	9.29	31.69	36.14	67.83
51	Douglas Co.	6	G	47	Timber Trail Elementary	2003	56,868	CHW System, HW reheat	9.24	31.53	36.49	68.02
52	Douglas Co.	6	G	22	Legacy Point Elementary	2003	56,868	CHW System, HW reheat	8.80	30.03	38.19	68.22
53	Douglas Co.	6	G	31	Pine Lane Elementary - South	1980	51,938	Rooftop DX, HW reheat	8.85	30.21	38.14	68.35
54	Douglas Co.	6	G	10	Cougar Run Elementary	1995	51,020	Rooftop DX, HW reheat	9.79	33.40	35.05	68.45
55	Denver	6	D	28	SOAR at Dennis Campus	2010	36,615	ground source heat pumps	18.02	61.47	7.20	68.67
56	Denver	6	D	67	Munroe Elementary	1961	61,232	none	5.04	17.20	51.76	68.96
57	Denver	6	D	51	Harrington Elementary	1993	54,003	central	9.78	33.37	36.28	69.65
58	Douglas Co.	6	G	27	Northeast Elementary	1966	47,660	CHW System, HW reheat, DX w/ gasf	7.23	24.66	45.91	70.56
59	Denver	6	D	62	Mckinley-Thatcher Elementa	1978	37,160	central	9.30	31.73	38.87	70.60
60	Denver	6	D	54	Kaiser Elementary	1973	64,725	central	9.84	33.58	37.05	70.64
61	Denver	6	D	59	Marrama Elementary	1984	68,706	indirect evaporative cooling	8.76	29.89	41.58	71.47
62	Denver	6	D	66	Moore	1889	72,334	none	4.59	15.67	56.73	72.41
63	Denver	6	D	58	Lowry Elementary	2001	60,893	central	11.79	40.24	32.86	73.10
64	Littleton	6	A	I	Moody	1953	39,364	Central Plant: Air Cooled Chiller	5.87	20.01	53.37	73.38
65	Denver	6	D	60	Maxwell Elementary	1998	63,864	central	4.63	15.80	58.08	73.88
66	Denver	6	D	65	Montclair School	1943	41,342	none	5.20	17.74	56.62	74.36
67	Denver	6	D	40	Ford Elementary	1973	63,160	central	13.74	46.89	27.47	74.36
68	Douglas Co.	6	G	15	Fox Creek Elementary	1995	54,020	Rooftop DX, HW reheat	9.36	31.94	42.82	74.76
69	Denver	6	D	74	Remington	1954	44,630	none	1.84	6.28	68.92	75.19
70	Denver	6	D	63	McMeen Elementary	1958	67,103	none	5.43	18.52	56.67	75.19
71	Denver	6	D	41	Garden Place Academy	1905	64,974	none	3.90	13.30	61.94	75.24
72	Douglas Co.	6	G	9	Copper Mesa Elementary	2005	56,566	CHW System, HW reheat	8.81	30.07	45.82	75.90
73	Douglas Co.	6	G	41	Sand Creek Elementary	1986	53,237	Rooftop DX, HW reheat	11.00	37.52	38.62	76.14
74	Douglas Co.	6	G	38	Roxborough Primary	1991	53,955	Rooftop DX, HW reheat	8.71	29.72	46.72	76.45
75	Douglas Co.	6	G	36	Rock Ridge Elementary	1988	53,237	Rooftop DX, HW reheat	9.10	31.06	45.46	76.52
76	Douglas Co.	6	G	26	Mountain View Elementary	1980	48,638	Rooftop DX, HW reheat	10.24	34.94	42.56	77.50
77	Denver	6	D	34	Ellis Elementary	1956	62,670	none	4.87	16.63	61.04	77.66
78	Douglas Co.	6	G	7	Cherry Valley Elementary	1952	4,657	Forced air, Split system A/C	23.07	78.73	-	78.73
79	Denver	6	D	3	Archuleta	2002	57,026	central	14.30	48.79	30.32	79.11
80	Denver	6	D	9	Beach Court Elementary	1929	44,706	none	4.83	16.47	63.26	79.73
81	Douglas Co.	6	G	34	Redstone Elementary	2005	56,566	CHW System, HW reheat	9.94	33.92	46.35	80.28

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
82	Denver	6	D	24	Cowell Elementary	1954	52,867	none	4.99	17.03	63.27	80.30
83	Denver	6	D	37	Fairview Elementary	1924	49,998	none	4.04	13.80	66.53	80.33
84	Denver	6	D	43	Godsman Elementary	1958	66,753	none	5.46	18.61	61.77	80.38
85	Denver	6	D	83	Southmoor Elementary	1974	39,640	roof top units	12.70	43.34	37.16	80.50
86	Douglas Co.	6	G	11	Coyote Creek Elementary	1995	54,220	Rooftop DX, HW reheat	10.67	36.42	44.41	80.83
87	Douglas Co.	6	G	43	Soaring Hawk Elementary	2004	56,566	CHW System, HW reheat	9.39	32.03	49.20	81.23
88	Denver	6	D	11	Bradley Elementary	1953	65,052	none	4.12	14.04	67.62	81.66
89	Douglas Co.	6	G	1	Acres Green Elementary	1975	50,480	Rooftop DX, HW reheat	8.51	29.04	52.75	81.79
90	Douglas Co.	6	G	19	Heritage Elementary	2001	51,688	CHW System, HW reheat	8.91	30.39	51.50	81.89
91	Denver	6	D	14	Bryant-Webster Dual Language	1930	56,824	none	4.46	15.22	67.03	82.25
92	Denver	6	D	68	Newlon Elementary	1951	71,901	none	6.40	21.84	60.56	82.41
93	Douglas Co.	6	G	13	Eldorado Elementary	2001	51,688	CHW System, HW reheat	9.43	32.18	50.32	82.50
94	Denver	6	D	8	Barrett Elementary	1960	38,755	none	5.60	19.09	63.85	82.94
95	Denver	6	D	27	Denison Montessori	1959	48,095	ground source heat pumps	7.49	25.55	57.99	83.54
96	Denver	6	D	82	Smith Renaissance of the A	1954	62,951	none	4.13	14.08	70.82	84.91
97	Douglas Co.	6	G	29	Pine Grove Elementary	1995	55,016	Rooftop DX, HW reheat	11.91	40.63	44.28	84.91
98	Denver	6	D	33	Edison Elementary	1925	49,261	none	5.51	18.81	66.15	84.96
99	Denver	6	D	22	Columbine Elementary	1959	48,869	central	5.40	18.42	66.91	85.33
100	Douglas Co.	6	G	14	Flagstone Elementary	2003	56,566	CHW System, HW reheat	9.27	31.64	54.40	86.04
101	Denver	6	D	93	Valverde Elementary	1923	46,021	none	5.47	18.67	67.79	86.47
102	Denver	6	D	55	Knapp Elementary	1956	77,127	none	4.71	16.07	70.44	86.52
103	Douglas Co.	6	G	32	Pioneer Elementary	1997	51,020	Rooftop DX, HW reheat	10.80	36.85	50.08	86.93
104	Douglas Co.	6	G	33	Prairie Crossing Elementary	2001	51,668	CHW System, HW reheat	11.50	39.25	47.73	86.98
105	Douglas Co.	6	G	42	Sedalia Elementary	1952	35,177	Rooftop DX, gasfired	8.26	28.18	59.24	87.43
106	Denver	6	D	20	College View Elementary	1995	46,483	central	11.56	39.43	48.19	87.62
107	Denver	6	D	38	Farrell B Howell	2006	97,968	central	12.39	42.29	45.55	87.84
108	Denver	6	D	19	Colfax Elementary	1920	35,715	central	12.87	43.90	44.10	88.00
109	Denver	6	D	4	Asbury Elementary	1925	39,994	none	4.46	15.22	73.05	88.27
110	Denver	6	D	44	Goldrick Elementary	1952	54,772	none	4.65	15.85	72.84	88.69
111	Denver	6	D	71	Park Hill Elementary	1901	68,743	roof top unit parial	5.98	20.40	68.79	89.19
112	Denver	6	D	61	McGlone Elementary	1978	59,562	central	13.24	45.16	44.06	89.23
113	Denver	6	D	84	Steck Elementary	1930	37,785	none	5.03	17.17	73.40	90.57
114	Douglas Co.	6	G	16	Franktown Elementary	1980	36,147	Rooftop DX, HW reheat	8.01	27.33	63.85	91.18

Group Rank	District	Region	District	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
115	Denver	6	D	89	Teller Elementary	1920	58,500	none	7.98	27.24	65.32	92.55
116	Denver	6	D	70	Palmer Elementary	1950	49,965	none	4.33	14.79	78.68	93.46
117	Douglas Co.	6	G	17	Frontier Valley Elementary	2003	55,868	CHW System, HW reheat	10.63	36.26	57.65	93.91
118	Douglas Co.	6	G	25	Meadow View Elementary	2000	51,668	CHW System, HW reheat	10.94	37.33	57.17	94.50
119	Denver	6	D	86	Steele Elementary	1913	54,513	none	5.61	19.14	75.75	94.89
120	Douglas Co.	6	G	48	Trailblazer Elementary	1997	51,020	Rooftop DX, HW reheat	11.35	38.73	56.31	95.05
121	Denver	6	D	64	Mitchell Elementary	1958	60,938	central	8.30	28.32	67.32	95.64
122	Denver	6	D	46	Green Valley Elementary	2000	67,612	central	13.52	46.13	50.04	96.16
123	Denver	6	D	7	Barnum Elementary	1921	64,535	central	8.80	30.03	66.47	96.51
124	Denver	6	D	49	Gust Elementary	1955	63,964	none	4.62	15.75	81.74	97.49
125	Denver	6	D	50	Hallett Fundamental Academy	1951	53,041	none	5.32	18.14	80.68	98.82
126	Denver	6	D	31	Egleton Elementary	1973	43,026	roof top unit	13.80	47.10	52.11	99.21
127	Denver	6	D	36	Fairmont Dual Language Academy	1924	59,635	central	7.04	24.02	76.49	100.51
128	Denver	6	D	13	Brown Elementary	1951	61,192	none	4.83	16.49	84.69	101.17
129	Denver	6	D	12	Bromwell Elementary	1975	37,016	none	10.22	34.86	66.62	101.48
130	Douglas Co.	6	G	28	Northridge Elementary	1982	48,055	CHW System, HW reheat	12.70	43.32	59.37	102.69
131	Denver	6	D	53	Johnson Elementary	1952	47,130	none	4.03	13.73	89.76	103.49
132	Denver	6	D	23	Cory Elementary	1950	44,436	none	3.95	13.47	90.99	104.45
133	Denver	6	D	80	Slavens Elementary	1956	54,900	none	4.81	16.41	88.87	105.28
134	Denver	6	D	39	Force Elementary	1955	63,591	none	4.13	14.08	91.30	105.38
135	Douglas Co.	6	G	2	Arrowwood Elementary	2000	51,668	CHW System, HW reheat	11.08	37.80	68.19	105.99
136	Denver	6	D	26	Del Pueblo Elementary	1973	39,991	roof top unit	11.99	40.92	68.16	109.08
137	Denver	6	D	29	Denver Green School @ Fallis	1960	41,237	none	6.00	20.46	89.22	109.68
138	Douglas Co.	6	G	20	Iron Horse Elementary	1998	51,020	CHW System, HW reheat	12.28	41.91	67.97	109.88
139	Douglas Co.	6	G	49	Wildcat Mountain Elementary	1998	51,676	CHW System, HW reheat	11.02	37.60	72.30	109.89
140	Denver	6	D	77	Samuels Elementary	1973	55,450	central	12.88	43.93	67.45	111.38
141	Denver	6	D	17	Centennial	1975	74,698	central	11.72	40.00	71.59	111.59
142	Denver	6	D	1	Amesse Elementary	1973	64,617	central	12.13	41.39	71.97	113.36
143	Denver	6	D	2	Ana Marie Sandoval	2001	37,639	central	19.07	65.07	48.71	113.77
144	Denver	6	D	30	Doull Elementary	1955	63,507	none	3.15	10.76	104.67	115.42
145	Denver	6	D	48	Greenwood Elementary	2001	66,136	central	14.01	47.79	68.43	116.22
146	Denver	6	D	25	Crofton Elementary	1919	24,877	none	2.46	8.38	108.85	117.23
147	Denver	6	D	42	Gilpin Elementary	1951	72,324	none	3.40	11.60	108.29	119.90

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
148	Denver	6	D	15	Carson Elementary	1950	44,825	none	4.52	15.42	104.97	120.39
149	Denver	6	D	96	Whiteman Elementary	1954	50,562	none	3.93	13.43	107.55	120.98
150	Denver	6	D	73	Pioneer Charter	Apr-05	37,084	none	5.28	18.02	103.14	121.16
151	Denver	6	D	56	Knight	1951	52,075	none	3.90	13.30	108.53	121.84
152	Denver	6	D	16	Castro Elementary	1993	66,944	central	15.17	51.75	73.68	125.43
153	Denver	6	D	85	Stedman Elementary	1923	45,763	none	5.72	19.53	106.12	125.64
154	Denver	6	D	72	Philips Preparatory	1951	35,005	water source heat pumps	4.93	16.82	109.16	125.98
155	Denver	6	D	18	Cheltenham Elementary	1970	73,106	central	9.07	30.95	96.42	127.37
156	Denver	6	D	6	Ashley Elementary	1921	46,912	none	5.50	18.78	110.09	128.88
157	Denver	6	D	81	Smedley Elementary	1902	61,611	none	6.39	21.82	108.59	130.40
158	Denver	6	D	52	Holm Elementary	1973	55,567	central	13.45	45.88	85.34	131.22
159	Denver	6	D	79	Schmitt Elementary	1955	49,326	none	4.08	13.93	118.52	132.45
160	Douglas Co.	6	G	21	Larkspur Elementary	1972	30,675	Rooftop DX, HW reheat	10.06	34.33	98.35	132.68
161	Denver	6	D	32	Ebert	1924	49,261	none	8.14	27.78	107.42	135.20
162	Denver	6	D	87	Swansea Elementary	1976	57,433	roof top units	14.36	49.00	91.02	140.01
163	Denver	6	D	97	Whittier	1930	46,460	central	8.35	28.50	121.19	149.69
164	Denver	6	D	92	Valdez Elementary	1974	64,880	central	13.29	45.35	110.59	155.94
	NOCO											
1	Poudre	2	C	E	Bethke	2008	62,691	IDEC	3.57	12.20	27.97	40.17
2	Poudre	2	C	R	McGraw	1993	51,384	None (Dx computer lab)	4.21	14.36	25.82	40.18
3	Poudre	2	C	W	Rice	2007	62,691	IDEC	4.09	13.95	26.77	40.72
4	Poudre	2	C	5	Zach	2002	67,412	Ice storage	5.27	17.97	23.47	41.44
5	Poudre	2	C	3	Traut	1998	50,871	None (Dx computer lab)	4.29	14.63	27.58	42.21
6	Poudre	2	C	A	Bacon	2003	65,299	Ice storage	4.97	16.97	27.94	44.91
7	Poudre	2	C	Q	Lopez	1986	57,639	None (Dx computer lab)	4.47	15.25	30.73	45.98
8	Poudre	2	C	I	Harris Bilingual	1919	38,599	None (Dx computer lab)	4.84	16.50	30.37	46.87
9	Poudre	2	C	Y	Shepardson	1978	51,964	None (Dx computer lab)	4.57	15.60	31.27	46.87
10	St. Vrain	2	A	D	Burlington Elementary	1966	47,200	RTU	5.89	20.08	27.18	47.26
11	Greeley	2	B	P	Winograd K-8	2003	69,426	Chiller & univents	4.49	15.33	32.87	48.21
12	St. Vrain	2	A	I	Erie Elementary	1966	49,667	RTU	6.55	22.36	25.98	48.33
13	Greeley	2	B	M	Scott	1963	54,378	Chiller & univents	4.59	15.67	33.82	49.49
14	Poudre	2	C	4	Werner	1987	53,180	None (Dx computer lab)	3.67	12.54	37.19	49.73

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
15	Poudre	2	C	B	Bauder	1968	63,156	None (Dx computer lab)	5.40	18.43	31.99	50.42
16	Greeley	2	B	I	McAuliffe	1988	49,925	Chiller & univents	7.97	27.19	23.41	50.60
17	St. Vrain	2	A	X	Sanborn Elementary	1984	49,000	CHILLER	5.56	18.98	32.81	51.79
18	St. Vrain	2	A	C	Blue Mountain Elementary	2008	51,801	RTU	7.27	24.80	27.07	51.87
19	Poudre	2	C	K	Johnson	1988	56,396	None (Dx computer lab)	4.09	13.95	38.70	52.65
20	Poudre	2	C	T	Olander	1990	51,384	None (Dx computer lab)	3.81	13.00	39.78	52.79
21	Poudre	2	C	L	Kruse	1992	52,824	None (Dx computer lab)	4.33	14.77	38.39	53.16
22	Poudre	2	C	O	Linton	1989	54,264	None (Dx computer lab)	3.85	13.13	41.76	54.89
23	Poudre	2	C	F	Cache la Poudre	1963	53,993	None (Dx computer lab)	4.45	15.19	40.01	55.20
24	Poudre	2	C	J	Irish	1968	53,731	None (Dx computer lab)	5.32	18.15	37.10	55.25
25	Poudre	2	C	N	Laurel	1993	51,384	None (Dx computer lab)	5.76	19.65	36.15	55.79
26	Poudre	2	C	H	Eyestone	1973	65,636	None (Dx computer lab)	5.53	18.88	37.11	55.99
27	St. Vrain	2	A	T	Niwot Elementary	1966	48,108	RTU	6.63	22.62	33.42	56.04
28	Greeley	2	B	O	Chappelow K-8	1986	64,193	Chiller & univents	8.28	28.24	28.06	56.30
29	Poudre	2	C	1	Tavelli	1968	63,977	None (Dx computer lab)	5.27	17.98	38.90	56.87
30	St. Vrain	2	A	O	Loma Linda Elementary	1970	47,138	CHILLER	6.31	21.52	36.03	57.55
31	St. Vrain	2	A	Q	Lyons Elementary	1956	43,315	RTU/CHILLER	6.06	20.67	38.14	58.81
32	St. Vrain	2	A	W	Rocky Mountain Elementary	19176	45,583	CHILLER	7.24	24.69	34.30	58.99
33	Poudre	2	C	C	Beattie	1972	45,655	None (Dx computer lab)	5.07	17.29	41.71	59.01
34	Greeley	2	B	A	Centennial	1975	50,083	Roof top DX units	9.57	32.66	27.91	60.57
35	St. Vrain	2	A	B	Black Rock Elementary	2008	55,497	RTU	8.00	27.29	33.32	60.61
36	St. Vrain	2	A	P	Longmont Estates Elementary	1971	45,562	CHILLER	6.49	22.15	38.49	60.64
37	Poudre	2	C	M	Lab School	1956	51,670	None (Dx computer lab)	4.50	15.35	45.31	60.66
38	St. Vrain	2	A	Y	Spangler Elementary	1962	48,509	CHILLER	5.68	19.39	41.37	60.75
39	St. Vrain	2	A	M	Indian Peaks Elementary	1976	44,438	CHILLER	7.89	26.91	34.75	61.65
40	St. Vrain	2	A	U	Northridge Elementary	1970	46,401	CHILLER	5.85	19.95	42.14	62.09
41	Greeley	2	B	J	Meeker	1975	41,111	Roof top DX units	11.98	40.86	21.53	62.39
42	Poudre	2	C	U	Putnam	1956	59,101	None (Dx computer lab)	5.14	17.54	45.13	62.67
43	St. Vrain	2	A	L	Hygiene Elementary	1972	44,246	CHILLER	6.58	22.45	40.31	62.77
44	St. Vrain	2	A	N	Legacy Elementary	2004	53,186	RTU	8.29	28.28	34.58	62.85
45	Greeley	2	B	N	Shawsheen	1975	35,135	Roof top DX units	12.93	44.11	18.88	62.99
46	Poudre	2	C	G	Dunn	1949	47,397	None (Dx computer lab)	5.06	17.28	46.29	63.57
47	St. Vrain	2	A	V	Prairie Ridge Elementary	2000	47,438	RTU	8.67	29.58	34.11	63.69

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
48	Poudre	2	C	S	O'Dea	1964	48,018	None (Dx computer lab)	4.47	15.26	48.49	63.75
49	Greeley	2	B	K	Monfort	1980	48,575	Chiller & univents	8.68	29.61	34.37	63.98
50	Poudre	2	C	Z	Stove Prairie	1896	8,809	None (Dx computer lab)	5.04	17.19	48.54	65.72
51	St. Vrain	2	A	G	Columbine Elementary	1906	64,471	RTU/CHILLER	5.51	18.79	46.97	65.76
52	St. Vrain	2	A	E	Centennial Elementary	2008	51,801	RTU	7.98	27.21	38.86	66.07
53	Greeley	2	B	E	Jackson	1958	48,395	Chiller & univents	7.88	26.89	39.28	66.17
54	St. Vrain	2	A	A	Alpine Elementary	2004	51,403	RTU	8.88	30.30	35.88	66.18
55	Greeley	2	B	L	Romero	2003	65,842	Chiller & univents	9.87	33.69	32.54	66.23
56	Greeley	2	B	B	Dos Rios	1988	49,444	Split system cooling	10.12	34.53	31.79	66.32
57	Poudre	2	C	P	Livermore	1953	11,292	None (Dx computer lab)	5.43	18.53	47.94	66.47
58	Greeley	2	B	D	Heiman	2003	69,074	Chiller & univents	9.49	32.36	34.57	66.93
59	Greeley	2	B	C	East Memorial	1964	48,896	Chiller & univents	10.44	35.62	32.66	68.28
60	St. Vrain	2	A	J	Fall River Elementary	2001	49,909	RTU	8.67	29.58	38.89	68.46
61	Poudre	2	C	D	Bennett	1963	50,492	None (Dx computer lab)	5.33	18.18	50.78	68.96
62	St. Vrain	2	A	F	Central Elementary	1878	57,547	RTU/CHILLER	7.68	26.20	45.20	71.40
63	St. Vrain	2	A	K	Frederick Elementary	1937	56,568	RTU	6.60	22.52	49.21	71.73
64	Greeley	2	B	G	Maplewood	1951	73,585	Chiller & univents	6.57	22.42	50.42	72.84
65	Poudre	2	C	X	Riffenburgh	1968	48,433	None (Dx computer lab)	4.82	16.45	56.73	73.17
66	St. Vrain	2	A	R	Mead Elemenetary	1930	48,242	RTU/CHILLER	5.95	20.30	53.40	73.70
67	Poudre	2	C	Z	Timnath	1919	69,112	None (Dx computer lab)	3.68	12.54	61.16	73.71
68	Greeley	2	B	F	Madison	1964	48,825	Roof top DX units	8.17	27.87	46.66	74.53
69	St. Vrain	2	A	H	Eagle Crest Elementary	1999	47,400	RTU	8.51	29.02	46.09	75.11
70	Greeley	2	B	H	Martinez	1951	59,185	Chiller & univents	4.11	14.02	63.79	77.81
71	Poudre	2	C	V	Red Feather	1985	9,001	None (Dx computer lab)	9.02	30.76	53.10	83.86
72	St. Vrain	2	A	S	Mtn View Elementary	1957	39,750	CHILLER	5.83	19.88	86.71	106.60
	NEBRASKA											
1	Grand Island	J	G	K	Wasmer Elementary	2000	67,000	Heat Pump	9.32	31.79	10.72	42.51
2	Grand Island	J	G	I	Seedling Mile Elementary	1955	25,600	Central	6.57	22.40	26.06	48.46
3	SSC	A	S	D	Harney Elem	1993	66,379	california heat pump loop	10.55	36.01	15.01	51.02
4	Grand Island	J	G	L	West Lawn Elementary	1995	47,800	Heat Pump	10.93	37.31	13.91	51.22
5	Grand Island	J	G	C	Dodge Elementary	1941	65,065	Heat Pump	11.61	39.60	13.98	53.58
6	Grand Island	J	G	G	Knickrehm Elementary	1966	39,856	Central	9.24	31.51	24.26	55.78

Group Rank	District	Region	Distict	School	2010-2011 Texas Elementary School Campus Name:	Year Built:	Temperature Controlled Square Footage:	Description of Air-Conditioning System: (None, Rooftop, Central, Heat Pump, Geothermal, etc.)	Elec KwHrs/SF	Elec Kbtu/SF	Gas Kbtu/SF	Total Kbtu/SF
7	Grand Island	J	G	A	Newell Elementary	1955	49,022	Central	9.33	31.85	27.02	58.87
8	Grand Island	J	G	B	Gates Elementary	1954	37,916	Roof Tops	8.36	28.51	31.73	60.24
9	SSC	A	S	B	Dakota City Elem	1948	37,748	Roof top	7.45	25.41	35.42	60.84
10	Kearney	J	K	K	Windy Hills Elementary	1981	32,205	Heat pump	11.56	39.44	23.60	63.04
11	Grand Island	J	G	E	Howard Elementary	1926	51,823	Central	10.32	35.20	28.72	63.92
12	Grand Island	J	G	H	Lincoln Elementary	1998	44,376	Heat Pump	13.61	46.43	17.65	64.08
13	SSC	A	S	F	Cardinal Elem	1993	64,328	california heat pump loop	9.71	33.14	32.17	65.31
14	SSC	A	S	E	Lewis & Clark Elem & Port	1959	25,037	roof top	7.87	26.84	42.23	69.08
15	Grand Island	J	G	F	Jefferson Elementary	1920	32,316	Central	12.46	42.51	26.75	69.25
16	Kearney	J	K	F	Meadowlark Elementary	1995	33,849	Heat pump	17.69	60.35	9.38	69.73
17	SSC	A	S	C	E N Swett Elem	1960	23,537	roof top	8.29	28.27	42.01	70.29
18	Kearney	J	K	J	Stone Elementary	1980	6,954	Forced air	8.25	28.14	42.95	71.10
19	Grand Island	J	G	M	Shoemaker Elementary	1977	49,297	Central and Roof Tops	15.40	52.55	18.67	71.23
20	Grand Island	J	G	D	Starr Elementary	1975	29,049	Central	12.70	43.32	34.56	77.88
21	Grand Island	J	G	J	Stolley Park Elementary	1886	26,423	Roof Tops	8.25	28.15	52.61	80.76
22	Kearney	J	K	C	Emerson Elementary	1950	27,306	Heat pump and window	9.97	34.03	47.59	81.63
23	SSC	A	S	A	Covington Elem	1924	52,015	closed loop-air handler	10.13	34.57	48.69	83.26
24	Kearney	J	K	B	Central Elementary	1927	71,829	Heat pump and window	9.19	31.34	52.46	83.80
25	Kearney	J	K	E	Kenwood Elementary	1934	34,879	Window	6.92	23.62	60.25	83.87
26	Kearney	J	K	G	Northeast Elementary	1958	44,156	HP and Central air	9.36	31.92	54.20	86.12
27	Kearney	J	K	H	Park Elementary	1950	30,752	Heat pump and window	7.68	26.22	61.27	87.49
28	Kearney	J	K	D	Glenwood Elementary	1979	14,751	Forced air	6.59	22.47	71.24	93.72
29	Grand Island	J	G	N	Engleman Elementary	1974	67,101	Central	15.00	51.16	45.10	96.26
30	Kearney	J	K	I	Riverdale Elementary	1938	11,563	Window	3.14	10.73	91.88	102.61
31	Kearney	J	K	A	Bryant Elementary	1950	25,526	Heat pump and window	9.65	32.92	78.42	111.34